

Evian Natural Spring Water California Bottled Water Report

THE STATE OF CALIFORNIA REQUIRES THE FOLLOWING INFORMATION TO BE PROVIDED TO BOTTLED WATER CONSUMERS, UPON REQUEST

Evian Natural Spring Water
Societe des Eaux Minerales d'Evian
c/o Danone Waters of America, Inc.
1 Maple Avenue
White Plains, NY 10605
1-800-633-3363

Source: Cachat Spring

Terms:

“statement of quality” – The standard (statement) of quality for bottled water is the highest level of a contaminant that is allowed in a container of bottled water, as established by the United States Food and Drug Administration (FDA) and the California Department of Public Health. The standards can be no less protective of public health than the standards for public drinking water, established by the U.S. Environmental Protection Agency (EPA) or the California Department of Public Health.

“maximum contaminant level (MCL)” – The highest level of a contaminant that is allowed in drinking water, established by the U.S. Environmental Protection Agency (EPA) or the California Department of Public Health. Primary MCLs are set as close to the PHGs as is economically and technologically feasible.

“public health goal (PHG)” – The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

“primary drinking water standard” – MCLs for contaminants established by the U.S. Environmental Protection Agency (EPA) or the California Department of Public Health that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Treatment Processes: Harmless naturally occurring iron and manganese minerals are removed for aesthetic purposes from less than 20% of the Evian Natural Spring Water resource through the use of Greensand Filtration (manganese dioxide sand).

FDA's website for recalls: <http://www.fda.gov/opacom/7alerts.html>

Our product has been thoroughly tested in accordance with federal and California law. Our bottled water is a food product and cannot be sold unless it meets the standards established by the U.S. Food and Drug Administration and the California Department of Public Health. The following statements are required under California law:

"Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the United States Food and Drug Administration, Food and Cosmetic Hotline (1-888-723-3366)."

Evian Natural Spring Water California Bottled Water Report

"Some persons may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, including, but not limited to, persons with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These persons should seek advice about drinking water from their health care providers. The United States Environmental Protection Agency and the Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791)."

"The sources of bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water naturally travels over the surface of the land or through the ground, it can pick up naturally occurring substances as well as substances that are present due to animal and human activity. Substances that may be present in the source water include any of the following:

- 1. Inorganic substances, including, but not limited to, salts and metals, that can be naturally occurring or result from farming, urban storm water runoff, industrial or domestic wastewater discharges, or oil and gas production.*
- 2. Pesticides and herbicides that may come from a variety of sources, including, but not limited to, agriculture, urban storm water runoff, and residential uses.*
- 3. Organic substances that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.*
- 4. Microbial organisms that may come from wildlife, agricultural livestock operations, sewage treatment plants, and septic systems.*
- 5. Substances with radioactive properties that can be naturally occurring or be the result of oil and gas production and mining activities."*

"In order to ensure that bottled water is safe to drink, the United States Food and Drug Administration and the State Department of Public Health prescribe regulations that limit the amount of certain contaminants in water provided by bottled water companies."



Send To: 40450

Ms. Alisa Kanjanakorn
Danone Foods Inc.
100 Hillside Avenue
White Plains, NY 10603

Facility: 40451

S.A. des Eaux Minerales d'Evian
B.P. 87, Place de la Gare
74503 Evian
Cedex
France

Result **PASS**

Final Report Date 07-MAR-2022

Customer Name S.A. des Eaux Minerales d'Evian
Tested To USFDA CFR Title 21 Part 165.110
Description Evian | Natural Spring Water
Test Type Annual Collection
Job Number A-00427895
Project Number 30034370 (CLAA)
Project Manager Kayla Anctil

Thank you for having your product tested by NSF International.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization *Nancy F. Cole*

Nancy Cole - Director, Analysis Laboratories

Date 07-MAR-2022



General Information

Standard: USFDA CFR Title 21 Part 165.110
Collected by: Joseph Tekieli | Sara Whitaker
Lot Number: PRD- 01 17 22 05:33- EXP-01 17 2024/ L4
Product Description: Evian | Natural Spring Water

Sample Id: **S-0001878890**
Description: Evian | Natural Spring Water - PRD- 01 17 22 05:33- EXP-01 17 2024/ L4
Sampled Date: 01/31/2022
Received Date: 01/28/2022

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Physical Quality					
Alkalinity as CaCO3	5	290		mg CaCO3/L	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	10	600		umhos/cm	
Corrosivity	0	0.488			
Hardness, Total	2	310		mg CaCO3/L	
Solids Total Dissolved	5	340	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	7.47			
Temperature	0	26		deg. C	
Odor, Threshold	1	ND	3	TON	Pass
Bicarbonate	5	289.4		mg CaCO3/L	
Disinfection Residuals/Disinfection By-Products					
Bromate	5	ND	10	ug/L	Pass
Monochloramine	0.05	ND		mg/L	
Dichloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chloramine, Total	0.05	ND	4	mg/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Monochloroacetic Acid	2	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Bromochloroacetic Acid	1	ND		ug/L	
Trichloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
Radiologicals					
Uranium	0.001	0.002	0.03	mg/L	Pass
Inorganic Chemicals					
Aluminum	0.01	ND	0.2	mg/L	Pass
Antimony	0.0002	0.0002	0.006	mg/L	Pass
Arsenic	0.001	ND	0.01	mg/L	Pass
* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas					
Chrysotile Fibers	0.2	ND		MFL	
Amphibole Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	
Barium	0.001	0.11	2	mg/L	Pass
Beryllium	0.0002	ND	0.004	mg/L	Pass
Bromide	10	12		ug/L	



Sample Id: S-0001878890

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.2	82		mg/L	
Chloride	2	11	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	0.004	0.1	mg/L	Pass
Copper	0.001	ND	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	ND	1.4	mg/L	Pass
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.2	26		mg/L	
Manganese	0.001	ND	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.0005	0.002	0.1	mg/L	Pass
Nitrogen, Nitrate	0.01	0.90	10	mg/L N	Pass
Nitrogen, Nitrite	0.004	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.01	0.90	10	mg/L	Pass
Potassium	0.5	1.0		mg/L	
Selenium	0.001	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.2	6.6		mg/L	
Sulfate as SO4	5	13	250	mg/L	Pass
MBAS, calc. as LAS Mol.Wt. 320	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref: EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	5	ND	30	pg/L	Pass
Carbamate Pesticides (Ref: 531.2)					
Aldicarb sulfoxide	0.5	ND		ug/L	
Aldicarb sulfone	0.5	ND		ug/L	
Oxamyl	0.5	ND	200	ug/L	Pass
Aldicarb	0.5	ND		ug/L	
Carbofuran	0.5	ND	40	ug/L	Pass
Methomyl	0.5	ND		ug/L	
Carbaryl	0.5	ND		ug/L	
3-Hydroxycarbofuran	0.5	ND		ug/L	
Semivolatile Organic Compounds (Ref: EPA 525.2)					
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
EPTC	0.5	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	



Sample Id: S-0001878890

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
2,6-Dinitrotoluene	0.5	ND		ug/L	
2,4 Dinitrotoluene	0.5	ND		ug/L	
Molinate	0.1	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Simazine	0.07	ND	4	ug/L	Pass
Atrazine	0.1	ND	3	ug/L	Pass
Lindane	0.02	ND	0.2	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Heptachlor	0.04	ND	0.4	ug/L	Pass
Di-n-butylphthalate	2	ND		ug/L	
Metolachlor	0.1	ND		ug/L	
Aldrin	0.1	ND		ug/L	
Heptachlor Epoxide	0.02	ND	0.2	ug/L	Pass
Butachlor	0.2	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
Butylbenzylphthalate	2	ND		ug/L	
bis(2-Ethylhexyl)adipate	0.6	ND	400	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	0.6	ND	6	ug/L	Pass
Benzo(a)Pyrene	0.02	ND	0.2	ug/L	Pass
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
Dichlorodifluoromethane	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass
Bromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
2,2-Dichloropropane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
Chloroform	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass



Sample Id: S-0001878890

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
Trichloroethylene	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
Bromodichloromethane	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
cis-1,3-Dichloropropene	0.5	ND		ug/L	
trans-1,3-Dichloropropene	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,3-Dichloropropane	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chlorobenzene	0.5	ND	100	ug/L	Pass
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methyl Ethyl Ketone	5	ND		ug/L	
Toluene	0.5	ND	1000	ug/L	Pass
Ethyl Benzene	0.5	ND	700	ug/L	Pass
m+p-Xylenes	1	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Bromobenzene	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
tert-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trimethylbenzene	0.5	ND		ug/L	
sec-Butylbenzene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
n-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
Chlorinated Pesticides and Organohalides by EPA 508.1					
Toxaphene	0.1	ND	3	ug/L	Pass
Chlordane	0.1	ND	2	ug/L	Pass
PCB 1016	0.08	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass



Sample Id: **S-0001878890**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass
Miscellaneous					
Dalapon	1	ND	200	ug/L	Pass
Dicamba	0.1	ND		ug/L	
2,4-D	0.1	ND	70	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
2,4,5-TP	0.2	ND	50	ug/L	Pass
Dinoseb	0.2	ND	7	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Bentazon	0.2	ND		ug/L	
DCPA Acid Metabolites	0.2	ND		ug/L	
NETFOSAA	2	ND		ng/L	
NMeFOSAA	2	ND		ng/L	
Perfluorobutanesulfonic acid	2	ND		ng/L	
Perfluorodecanoic acid	2	ND		ng/L	
Perfluorododecanoic acid	2	ND		ng/L	
Perfluoroheptanoic acid	2	ND		ng/L	
Perfluorohexanesulfonic acid	2	ND		ng/L	
Perfluorohexanoic acid	2	ND		ng/L	
Perfluorononanoic acid	2	ND		ng/L	
Perfluorooctanesulfonic acid	2	ND		ng/L	
Perfluorooctanoic acid	2	ND		ng/L	
Perfluorotetradecanoic acid	2	ND		ng/L	
Perfluorotridecanoic acid	2	ND		ng/L	
Perfluoroundecanoic acid	2	ND		ng/L	
HFPO-DA/GenX	2	ND		ng/L	
ADONA	2	ND		ng/L	
9Cl-PF3ONS/F-53B Major	2	ND		ng/L	
11Cl-PF3OUdS/F-53B Minor	2	ND		ng/L	
1,4-Dioxane	5	ND		ug/L	

Sample Id: **S-0001885545**

Description: Evian | Natural Spring Water - PRD- 01 17 22 05:33- EXP-01 17 2024/ L4

Sampled Date: 02/22/2022

Received Date: 01/28/2022

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Miscellaneous					
1,2,3-Trichloropropane	0.005	ND		ug/L	



<<Additional Information>>

Sample Id: S-0001878890

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	4-FEB-2022		
Color (Ref: SM 2120-B)	31-JAN-2022	14:20	
Specific Conductance (Ref: EPA 120.1)	31-JAN-2022		
Corrosivity (Ref: SM 2330-B)			
Test Notes			
The corrosivity calculation uses half of the reporting limit for any calcium and/or bicarbonate/alkalinity value that has a result of less than the reporting limit.			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	3-FEB-2022		
Turbidity (Ref: EPA 180.1)	31-JAN-2022	14:35	
pH (Ref: SM4500-HB)	31-JAN-2022	13:54	
#1 Odor, Threshold Number Eurofins Monrovia (Ref. Standard Method 2150 B)	2-FEB-2022	9:48	
*Bicarbonate (Ref: SM 4500-D)			
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	2-FEB-2022		
Chloramines (Ref: SM 4500-Cl-G)	31-JAN-2022	12:13	
Chlorite (Ref: EPA 300.1)	2-FEB-2022		
Chlorine Dioxide (Ref: SM 4500-ClO2-D)	31-JAN-2022	12:13	
Haloacetic Acids (Ref: EPA 552.2)	14-FEB-2022		10-FEB-2022
Chlorine, Total Residual (ref. SM 4500CL-G)	31-JAN-2022	12:13	
Radiologicals			
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	2-FEB-2022		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
#3 * Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas	11-FEB-2022	18:00	
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Bromide (Ref: EPA 300.1)	2-FEB-2022		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Chloride (Ref: EPA 300.0)	31-JAN-2022		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)			



<<Additional Information>>

Sample Id: S-0001878890

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
	2-FEB-2022		
Cyanide, Total (Ref: EPA 335.4)	3-FEB-2022		
Fluoride (Ref: SM 4500-F-C)	1-FEB-2022		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Nitrogen, Nitrate (Ref: EPA 300.0)	31-JAN-2022	13:52	
Nitrogen, Nitrite (Ref: EPA 300.0)	31-JAN-2022	13:52	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ	1-FEB-2022		31-JAN-2022
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Sulfate as SO4 (Ref: EPA 300.0)	31-JAN-2022		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	31-JAN-2022	16:02	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
* Phenolics, Total Recoverable (Based on EPA 420.4)	1-FEB-2022		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Organic Chemicals			
Diquat (Ref: EPA 549.2)	14-FEB-2022		10-FEB-2022
Endothall (Ref: EPA 548.1) - (ug/L)	7-FEB-2022		4-FEB-2022
Glyphosate (Ref: EPA 547)	31-JAN-2022		
Perchlorate (Ref: EPA 314.0)	16-FEB-2022		
2,3,7,8-TCDD (Ref: EPA 1613B)	7-FEB-2022		6-FEB-2022
Carbamate Pesticides (Ref: 531.2)	7-FEB-2022		
Semivolatile Organic Compounds (Ref: EPA 525.2)	17-FEB-2022		15-FEB-2022
Volatiles: EDB and DBCP (Ref: EPA 504.1)	2-FEB-2022		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	2-FEB-2022		
Chlorinated Pesticides and Organohalides by EPA 508.1	4-FEB-2022		
Miscellaneous			
* Dioxane, 1,4-, P&T GC/MS			



<<Additional Information>>

Sample Id: S-0001878890

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Miscellaneous			
* Herbicides (Ref: EPA 515.4)	14-FEB-2022		11-FEB-2022
#2 *Perfluorinated Compounds (PFC's) by EPA 537.1 - Eurofins Eaton Analytical	9-FEB-2022		



<<Additional Information>>

Sample Id: S-0001885545

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Miscellaneous			
#2 * 1,2,3-Trichloropropane (Low Level EPA 524M) at Eurofins Eaton Analytical	25-FEB-2022		



Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified)	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
#1	EEA	Eurofins Eaton Analytical, Inc. 750 Royal Oaks Dr, Suite 100 Monrovia, CA 91016 NY Lic. # 11320 MI Lic. # 9906
#3	EURO_EATON	Eurofins Eaton Analytical, Inc. 110 South Hill Street South Bend, IN 46617 USA
#2	MAXXAM	Maxxam - a Bureau Veritas Company 3380 Chastain Meadows Pkwy 300 Kennesaw, GA 30144 Arizona License #AZ0675 NY Lic. # 11645 MI Lic. # 9955

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C1294	* 1,2,3-Trichloropropane (Low Level EPA 524M) at Eurofins Eaton Analytical
C1295	Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ
C1302	* Herbicides (Ref: EPA 515.4)
C1310	*Perfluorinated Compounds (PFC's) by EPA 537.1 - Eurofins Eaton Analytical
C1358	Odor, Threshold Number Eurofins Monrovia (Ref. Standard Method 2150 B)
C1361	*Bicarbonate (Ref: SM 4500-D)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3012	* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	* Phenolics, Total Recoverable (Based on EPA 420.4)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)



References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3168	Chlorine Dioxide (Ref: SM 4500-CIO2-D)
C3169	Chloramines (Ref: SM 4500-CI-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4076	Carbamate Pesticides (Ref: 531.2)
C4137	* Dioxane, 1,4-, P&T GC/MS
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref: EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1

Laboratory Certifications:

Arizona (# AZ0655)	California (# 03214 CA)	Connecticut (# PH-0625)
Florida (# E-87752 FL)	Hawaii	Indiana
Maryland (# 201)	Michigan (# 0048)	North Carolina (# 26701)
New Jersey (# MI770)	Nevada (# MI000302010A)	New York (# 11206)
Pennsylvania (# 68-00312)	South Carolina (# 81005)	Virginia (# 00045)
Vermont (# VT 11206)		

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its 17025 scope of accreditation.

Unless otherwise indicated, method uncertainties are not applied in any determinations of conformity. Testing utilizes the requested sections of any referenced standards, which may not be the entire standard.

Dates of Laboratory Activity: 31-JAN-2022 to 07-MAR-2022

The reported result for Total Recoverable Phenolics, Potassium, Molybdenum, Silica, Total Phosphorus, Radon, Sr-89/90, Bicarbonate, Bromochloroacetic Acid, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane if performed, cannot be used for compliance purposes within the State of Arizona.



Certifications are not offered for these compounds in a drinking water matrix.

The reported results for Total Recoverable Phenolics, pH, Bicarbonate if performed, are not covered by New York State drinking water certifications. NSF is not certified for Chlorine Dioxide, Chloramines, Total Residual Chlorine, Bromochloroacetic Acid, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane in the State of New York.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF International Method Detection Limits refer to https://d2evkimvhatqav.cloudfront.net/documents/external/minimum_detection_level_spreadsheet.pdf



Send To: 40450

Ms. Alisa Kanjanakorn
Danone Foods Inc.
100 Hillside Avenue
White Plains, NY 10603

Facility: 40451

S.A. des Eaux Minerales d'Evian
B.P. 87, Place de la Gare
74503 Evian
Cedex
France

Result **PASS**

Final Report Date 07-MAR-2022

Customer Name	S.A. des Eaux Minerales d'Evian
Tested To	USFDA CFR Title 21 Part 165.110
Description	Evian Sparkling Spring Water
Test Type	Annual Collection
Job Number	J-00428406
Project Number	30034370 (CLAG)
Project Manager	Kayla Anctil

Thank you for having your product tested by NSF International.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization *Nancy F. Cole*

Nancy Cole - Director, Analysis Laboratories

Date 07-MAR-2022



General Information

Standard: USFDA CFR Title 21 Part 165.110
Collected by: Joseph Tekieli | Sara Whitaker
Lot Number: PRD 19 11 21 11:27 EXP 19 11 23 R
Product Description: Evian | Sparkling Spring Water

Sample Id: **S-0001878886**
Description: Evian | Sparkling Spring Water - PRD 19 11 21 11:27 EXP 19 11 23 R
Sampled Date: 01/31/2022
Received Date: 01/28/2022

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Physical Quality					
Alkalinity as CaCO3	5	290		mg CaCO3/L	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	10	600		umhos/cm	
Corrosivity	0	-1.435			
Hardness, Total	2	310		mg CaCO3/L	
Solids Total Dissolved	5	320	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	5.55			
Temperature	0	26		deg. C	
Odor, Threshold	1	ND	3	TON	Pass
Bicarbonate	5	286.8		mg CaCO3/L	
Disinfection Residuals/Disinfection By-Products					
Bromate	5	ND	10	ug/L	Pass
Monochloramine	0.05	ND		mg/L	
Dichloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chloramine, Total	0.05	ND	4	mg/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Monochloroacetic Acid	2	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Bromochloroacetic Acid	1	ND		ug/L	
Trichloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
Radiologicals					
Uranium	0.001	0.002	0.03	mg/L	Pass
Inorganic Chemicals					
Aluminum	0.01	ND	0.2	mg/L	Pass
Antimony	0.0002	ND	0.006	mg/L	Pass
Arsenic	0.001	ND	0.01	mg/L	Pass
* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas					
Chrysotile Fibers	0.2	ND		MFL	
Amphibole Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	
Barium	0.001	0.11	2	mg/L	Pass
Beryllium	0.0002	ND	0.004	mg/L	Pass
Bromide	10	12		ug/L	

Sample Id: **S-0001878886**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.2	82		mg/L	
Chloride	2	11	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	0.031	0.1	mg/L	Pass
Copper	0.001	ND	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	0.1	2.4	mg/L	Pass
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.2	27		mg/L	
Manganese	0.001	ND	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.0005	0.002	0.1	mg/L	Pass
Nitrogen, Nitrate	0.01	0.89	10	mg/L N	Pass
Nitrogen, Nitrite	0.004	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.01	0.89	10	mg/L	Pass
Potassium	0.5	1.1		mg/L	
Selenium	0.001	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.2	6.5		mg/L	
Sulfate as SO4	2.5	11	250	mg/L	Pass
MBAS, calc. as LAS Mol.Wt. 320	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref: EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	5	ND	30	pg/L	Pass
Carbamate Pesticides (Ref: 531.2)					
Aldicarb sulfoxide	0.5	ND		ug/L	
Aldicarb sulfone	0.5	ND		ug/L	
Oxamyl	0.5	ND	200	ug/L	Pass
Aldicarb	0.5	ND		ug/L	
Carbofuran	0.5	ND	40	ug/L	Pass
Methomyl	0.5	ND		ug/L	
Carbaryl	0.5	ND		ug/L	
3-Hydroxycarbofuran	0.5	ND		ug/L	
Semivolatile Organic Compounds (Ref: EPA 525.2)					
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
EPTC	0.5	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	



Sample Id: S-0001878886

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
2,6-Dinitrotoluene	0.5	ND		ug/L	
2,4 Dinitrotoluene	0.5	ND		ug/L	
Molinate	0.1	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Simazine	0.07	ND	4	ug/L	Pass
Atrazine	0.1	ND	3	ug/L	Pass
Lindane	0.02	ND	0.2	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Heptachlor	0.04	ND	0.4	ug/L	Pass
Di-n-butylphthalate	2	ND		ug/L	
Metolachlor	0.1	ND		ug/L	
Aldrin	0.1	ND		ug/L	
Heptachlor Epoxide	0.02	ND	0.2	ug/L	Pass
Butachlor	0.2	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
Butylbenzylphthalate	2	ND		ug/L	
bis(2-Ethylhexyl)adipate	0.6	ND	400	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	0.6	ND	6	ug/L	Pass
Benzo(a)Pyrene	0.02	ND	0.2	ug/L	Pass
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
Dichlorodifluoromethane	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass
Bromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
2,2-Dichloropropane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
Chloroform	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass



Sample Id: S-0001878886

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
Trichloroethylene	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
Bromodichloromethane	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
cis-1,3-Dichloropropene	0.5	ND		ug/L	
trans-1,3-Dichloropropene	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,3-Dichloropropane	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chlorobenzene	0.5	ND	100	ug/L	Pass
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methyl Ethyl Ketone	5	ND		ug/L	
Toluene	0.5	ND	1000	ug/L	Pass
Ethyl Benzene	0.5	ND	700	ug/L	Pass
m+p-Xylenes	1	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Bromobenzene	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
tert-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trimethylbenzene	0.5	ND		ug/L	
sec-Butylbenzene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
n-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
Chlorinated Pesticides and Organohalides by EPA 508.1					
Toxaphene	0.1	ND	3	ug/L	Pass
Chlordane	0.1	ND	2	ug/L	Pass
PCB 1016	0.08	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass



Sample Id: **S-0001878886**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass
Miscellaneous					
Dalapon	1	ND	200	ug/L	Pass
Dicamba	0.1	ND		ug/L	
2,4-D	0.1	ND	70	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
2,4,5-TP	0.2	ND	50	ug/L	Pass
Dinoseb	0.2	ND	7	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Bentazon	0.2	ND		ug/L	
DCPA Acid Metabolites	0.2	ND		ug/L	
NEtFOSAA	2	ND		ng/L	
NMeFOSAA	2	ND		ng/L	
Perfluorobutanesulfonic acid	2	ND		ng/L	
Perfluorodecanoic acid	2	ND		ng/L	
Perfluorododecanoic acid	2	ND		ng/L	
Perfluoroheptanoic acid	2	ND		ng/L	
Perfluorohexanesulfonic acid	2	ND		ng/L	
Perfluorohexanoic acid	2	ND		ng/L	
Perfluorononanoic acid	2	ND		ng/L	
Perfluorooctanesulfonic acid	2	ND		ng/L	
Perfluorooctanoic acid	2	ND		ng/L	
Perfluorotetradecanoic acid	2	ND		ng/L	
Perfluorotridecanoic acid	2	ND		ng/L	
Perfluoroundecanoic acid	2	ND		ng/L	
HFPO-DA/GenX	2	ND		ng/L	
ADONA	2	ND		ng/L	
9Cl-PF3ONS/F-53B Major	2	ND		ng/L	
11Cl-PF3OUdS/F-53B Minor	2	ND		ng/L	

Sample Id: **S-0001885546**

Description: Evian | Sparkling Spring Water - PRD 19 11 21 11:27 EXP 19 11 23 R

Sampled Date: 02/22/2022

Received Date: 01/28/2022

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Miscellaneous					
1,2,3-Trichloropropane	0.005	ND		ug/L	



<<Additional Information>>

Sample Id: S-0001878886

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	4-FEB-2022		
Color (Ref: SM 2120-B)	31-JAN-2022	14:20	
Specific Conductance (Ref: EPA 120.1)	31-JAN-2022		
Corrosivity (Ref: SM 2330-B)			
Test Notes			
The corrosivity calculation uses half of the reporting limit for any calcium and/or bicarbonate/alkalinity value that has a result of less than the reporting limit.			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	3-FEB-2022		
Turbidity (Ref: EPA 180.1)	31-JAN-2022	14:35	
pH (Ref: SM4500-HB)	31-JAN-2022	12:00	
#1 Odor, Threshold Number Eurofins Monrovia (Ref. Standard Method 2150 B)	2-FEB-2022	9:49	
*Bicarbonate (Ref: SM 4500-D)			
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	2-FEB-2022		
Chloramines (Ref: SM 4500-Cl-G)	31-JAN-2022	11:59	
Chlorite (Ref: EPA 300.1)	2-FEB-2022		
Chlorine Dioxide (Ref: SM 4500-ClO2-D)	31-JAN-2022	11:59	
Haloacetic Acids (Ref: EPA 552.2)	14-FEB-2022		10-FEB-2022
Chlorine, Total Residual (ref. SM 4500CL-G)	31-JAN-2022	11:59	
Radiologicals			
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	2-FEB-2022		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
#3 * Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas	11-FEB-2022	18:00	
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Bromide (Ref: EPA 300.1)	2-FEB-2022		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Chloride (Ref: EPA 300.0)	31-JAN-2022		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)			



<<Additional Information>>

Sample Id: S-0001878886

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
	2-FEB-2022		
Cyanide, Total (Ref: EPA 335.4)	3-FEB-2022		
Fluoride (Ref: SM 4500-F-C)	1-FEB-2022		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Nitrogen, Nitrate (Ref: EPA 300.0)	31-JAN-2022	10:53	
Nitrogen, Nitrite (Ref: EPA 300.0)	31-JAN-2022	10:53	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ	1-FEB-2022		31-JAN-2022
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	2-FEB-2022		
Sulfate as SO4 (Ref: EPA 300.0)	31-JAN-2022		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	31-JAN-2022	16:02	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
* Phenolics, Total Recoverable (Based on EPA 420.4)	1-FEB-2022		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	2-FEB-2022		
Organic Chemicals			
Diquat (Ref: EPA 549.2)	14-FEB-2022		10-FEB-2022
Endothall (Ref: EPA 548.1) - (ug/L)	7-FEB-2022		4-FEB-2022
Glyphosate (Ref: EPA 547)	31-JAN-2022		
Perchlorate (Ref: EPA 314.0)	16-FEB-2022		
2,3,7,8-TCDD (Ref: EPA 1613B)	7-FEB-2022		6-FEB-2022
Carbamate Pesticides (Ref: 531.2)	7-FEB-2022		
Semivolatile Organic Compounds (Ref: EPA 525.2)	17-FEB-2022		15-FEB-2022
Volatiles: EDB and DBCP (Ref: EPA 504.1)	7-FEB-2022		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	2-FEB-2022		
Chlorinated Pesticides and Organohalides by EPA 508.1	4-FEB-2022		
Miscellaneous			
* Herbicides (Ref: EPA 515.4)	14-FEB-2022		11-FEB-2022



<<Additional Information>>

Sample Id: S-0001878886

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Miscellaneous			
#2 *Perfluorinated Compounds (PFC's) by EPA 537.1 - Eurofins Eaton Analytical	9-FEB-2022		



<<Additional Information>>

Sample Id: S-0001885546

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Miscellaneous			
#2 * 1,2,3-Trichloropropane (Low Level EPA 524M) at Eurofins Eaton Analytical	25-MAR-2022		



Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified)	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
#1	EEA	Eurofins Eaton Analytical, Inc. 750 Royal Oaks Dr, Suite 100 Monrovia, CA 91016 NY Lic. # 11320 MI Lic. # 9906
#3	EURO_EATON	Eurofins Eaton Analytical, Inc. 110 South Hill Street South Bend, IN 46617 USA
#2	MAXXAM	Maxxam - a Bureau Veritas Company 3380 Chastain Meadows Pkwy 300 Kennesaw, GA 30144 Arizona License #AZ0675 NY Lic. # 11645 MI Lic. # 9955

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C1294	* 1,2,3-Trichloropropane (Low Level EPA 524M) at Eurofins Eaton Analytical
C1295	Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ
C1302	* Herbicides (Ref: EPA 515.4)
C1310	*Perfluorinated Compounds (PFC's) by EPA 537.1 - Eurofins Eaton Analytical
C1358	Odor, Threshold Number Eurofins Monrovia (Ref. Standard Method 2150 B)
C1361	*Bicarbonate (Ref: SM 4500-D)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3012	* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	* Phenolics, Total Recoverable (Based on EPA 420.4)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)



References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3168	Chlorine Dioxide (Ref: SM 4500-CIO2-D)
C3169	Chloramines (Ref: SM 4500-CI-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref. EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1

Laboratory Certifications:

Arizona (# AZ0655)	California (# 03214 CA)	Connecticut (# PH-0625)
Florida (# E-87752 FL)	Hawaii	Indiana
Maryland (# 201)	Michigan (# 0048)	North Carolina (# 26701)
New Jersey (# MI770)	Nevada (# MI000302010A)	New York (# 11206)
Pennsylvania (# 68-00312)	South Carolina (# 81005)	Virginia (# 00045)
Vermont (# VT 11206)		

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its 17025 scope of accreditation.

Unless otherwise indicated, method uncertainties are not applied in any determinations of conformity. Testing utilizes the requested sections of any referenced standards, which may not be the entire standard.

Dates of Laboratory Activity: 31-JAN-2022 to 07-MAR-2022

The reported result for Total Recoverable Phenolics, Potassium, Molybdenum, Silica, Total Phosphorus, Radon, Sr-89/90, Bicarbonate, Bromochloroacetic Acid, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane if performed, cannot be used for compliance purposes within the State of Arizona. Certifications are not offered for these compounds in a drinking water matrix.



The reported results for Total Recoverable Phenolics, pH, Bicarbonate if performed, are not covered by New York State drinking water certifications. NSF is not certified for Chlorine Dioxide, Chloramines, Total Residual Chlorine, Bromochloroacetic Acid, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane in the State of New York.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF International Method Detection Limits refer to

https://d2evkimvhatqav.cloudfront.net/documents/external/minimum_detection_level_spreadsheet.pdf